



CONSTRUCTION NOTES:

1. PIPE AND FITTINGS SHALL BE AT LEAST FOUR (4) INCHES IN DIAMETER. PIPE BEDDING TO BE AS SPECIFIED.
2. PIPE AND FITTINGS OTHER THAN TRAP, VENT & CLEANOUT SHALL BE POLYVINYL CHLORIDE SDR-35 (PVC) PIPE CONFORMING TO ASTM D-3034. SCHEDULE 40, ASTM D-1785 PVC PIPE MAY BE USED IF TRENCH IS NOT WET AND IF APPROVED BY THE AUTHORITY'S INSPECTOR.
3. JOINTS SHALL BE GASKET TYPE, ASTM F-477, FOR ASTM D-3034, SDR-35 PIPE & PURPLE PRIMED, ASTM F-656, AND SOLVENT CEMENTED, ASTM D-2564, FOR SCHEDULE 40 PIPE.
4. BUILDING SEWER SHALL BE LAID ON A GRADE OF NOT LESS THAN ONE-QUARTER (1/4) OF AN INCH PER FOOT TOWARD THE SANITARY SEWER MAIN. ABSOLUTE MINIMUM ALLOWABLE GRADE SHALL BE ONE-EIGHTH (1/8) OF AN INCH PER FOOT.
5. PROVIDE A MINIMUM COVER OF TWO AND ONE-HALF (2-1/2) FEET FOR BUILDING SEWER.
6. A CLAY TRENCH PLUG NEAR THE VIEW PORT IS AN OPTION TO BE CONSIDERED BY THE PROPERTY OWNER.

HOLLIDAYSBURG SEWER AUTHORITY
TYPICAL BUILDING SEWER CONNECTION
 (N.T.S.)